

DMR Copy of Record

Permit																					
Permit #:	IL0021288	Permittee:	GREATER PEORIA SANITARY AND SEWAGE DISTRICT							Facility:	GREATER PEORIA SANITARY AND SEWAGE DISTRICT										
Major:	Yes	Permittee Address:	2322 SOUTH DARST STREET PEORIA, IL 61607							Facility Location:	2322 SOUTH DARST STREET PEORIA, IL 61607										
Permitted Feature:	001 External Outfall	Discharge:	001-0 STP OUTFALL																		
Report Dates & Status																					
Monitoring Period:	From 06/01/16 to 06/30/16							DMR Due Date:	07/25/16							Status:	NetDMR Validated				
Considerations for Form Completion																					
DMF LOAD LIMITS DISPLAYED																					
Principal Executive Officer																					
First Name:	Stanton							Title:	Executive Director							Telephone:	309-637-3511				
Last Name:	Browning																				
No Data Indicator (NODI)																					
Form NODI:	--																				
Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type				
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units					
00400	pH	1 - Effluent Gross	0	--	Sample					=	7.4			=	7.9	12 - SU	0	05/DW - 5 Days Every Week	GR - GRAB		
					Permit Req.					>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU	0	02/DA - 2 Days Every Week	GR - GRAB		
					Value NODI																
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	1308	=	1773	26 - lb/d		=	8	=	11	19 - mg/L	0	06/07 - Six Every Week	CP - COMPOS		
					Permit Req.	<=	12510 MO AVG	<=	22518 WKLY AVG	26 - lb/d		<=	25 MO AVG	<=	45 WKLY AVG	19 - mg/L	0	02/DA - 2 Days Every Week	CP - COMPOS		
					Value NODI																
00600	Nitrogen, total [as N]	1 - Effluent Gross	0	--	Sample						=	18.79				19 - mg/L	0	01/07 - Weekly	CP - COMPOS		
					Permit Req.							Req Mon MO AVG				19 - mg/L	0	01/30 - Monthly	CP - COMPOS		
					Value NODI																
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	5	--	Sample	=	289	=	1190	26 - lb/d		=	1.7	=	3.6	19 - mg/L	0	06/07 - Six Every Week	CP - COMPOS		
					Permit Req.	<=	1251 MO AVG	<=	2502 DAILY MX	26 - lb/d		<=	2.5 MO AVG	<=	5 DAILY MX	19 - mg/L	0	02/DA - 2 Days Every Week	CP - COMPOS		
					Value NODI																
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample						=	2.55				19 - mg/L	0	01/07 - Weekly	CP - COMPOS		
					Permit Req.							Req Mon MO AVG				19 - mg/L	0	01/30 - Monthly	CP - COMPOS		
					Value NODI																
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	19.56	=	46.03	03 - MGD							0	99/99 - Continuous	RT - RCOTOT		
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	03 - MGD							0	99/99 - Continuous	RT - RCOTOT		
					Value NODI																
50060	Chlorine, total residual	1 - Effluent Gross	2	--	Sample						<	0.02		=	0.02	19 - mg/L	0	05/DW - 5 Days Every Week	GR - GRAB		
					Permit Req.						<=	.15 MO AVG		<=	.75 DAILY MX	19 - mg/L	0	05/DW - 5 Days Every Week	GR - GRAB		
					Value NODI																
74055	Coliform, fecal general	1 - Effluent Gross	0	--	Sample									=	120	13 - #/100mL	0	05/DW - 5 Days Every Week	GR - GRAB		
					Permit Req.									<=	400 DAILY MX	13 - #/100mL	0	05/DW - 5 Days Every Week	GR - GRAB		
					Value NODI																
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample	=	489	=	711	26 - lb/d		<	3	<	4	19 - mg/L	0	05/DW - 5 Days Every Week	CP - COMPOS		
					Permit Req.	<=	10008 MO AVG	<=	20016 WKLY AVG	26 - lb/d		<=	20 MO AVG	<=	40 WKLY AVG	19 - mg/L	0	02/DA - 2 Days Every Week	CP - COMPOS		
					Value NODI																
Submission Note																					
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.																					
Edit Check Errors																					
No errors.																					
Comments																					
All CSO Regulators were open in June 2016.																					
Attachments																					
No attachments.																					
Report Last Saved By																					
GREATER PEORIA SANITARY AND SEWAGE DISTRICT																					
User:	pkturi@gpsd.org							Date/Time:	2016-07-15 14:58 (Time Zone: -05:00)												
Name:	Paul Keturi																				
E-Mail:	pkturi@gpsd.org																				

DMR Copy of Record

Permit		Permittee:		Facility:															
Permit #:	IL0021288	GREATER PEORIA SANITARY AND SEWAGE DISTRICT		GREATER PEORIA SANITARY AND SEWAGE DISTRICT															
Major:	Yes	Permittee Address: 2322 SOUTH DARST STREET PEORIA, IL 61607		Facility Location: 2322 SOUTH DARST STREET PEORIA, IL 61607															
Permitted Feature:	002 External Outfall	Discharge: 002-0 EMERGENCY HIGH LEVEL BYPASS																	
Report Dates & Status																			
Monitoring Period:	From 06/01/16 to 06/30/16	DMR Due Date:	07/25/16	Status:	NetDMR Validated														
Considerations for Form Completion																			
CS																			
Principal Executive Officer																			
First Name:	Title:			Telephone:															
Last Name:																			
No Data Indicator (NODI)																			
Form NODI:	--																		
Parameter	Monitoring Location	Season #	Param. NODI	Quantity or Loading			Quality or Concentration			# of Ex.	Frequency of Analysis	Sample Type							
Code	Name			Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units				
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--															
00530	Solids, total suspended	1 - Effluent Gross	0	--															
74071	Flow	1 - Effluent Gross	0	--															
Submission Note																			
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.																			
Edit Check Errors																			
No errors.																			
Comments																			
Attachments																			
No attachments.																			
Report Last Saved By																			
GREATER PEORIA SANITARY AND SEWAGE DISTRICT																			
User:	mgibbs@gpsd.org			Date/Time:	2016-07-15 14:51 (Time Zone: -05:00)														
Name:	Mike Gibbs																		
E-Mail:	mgibbs@gpsd.org																		

DMR Copy of Record

Permit			
Permit #:	IL0021288	Permittee:	GREATER PEORIA SANITARY AND SEWAGE DISTRICT
Major:	Yes	Permittee Address:	2322 SOUTH DARST STREET PEORIA, IL 61607
Permitted Feature:	003 External Outfall	Discharge:	003-0 SECONDARY OUTFALL
Facility:	GREATER PEORIA SANITARY AND SEWAGE DISTRICT		
Facility Location:	2322 SOUTH DARST STREET PEORIA, IL 61607		

Report Dates & Status

Monitoring Period:	From 06/01/16 to 06/30/16	DMR Due Date:	07/25/16	Status:	NetDMR Validated
--------------------	---------------------------	---------------	----------	---------	------------------

Considerations for Form Completion

DMF LOAD LIMITS DISPLAYED.CS

Principal Executive Officer

First Name:	Title:	Telephone:
Last Name:		

No Data Indicator (NODI)

Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type	
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3				Units
00400	pH	1 - Effluent Gross	0	--	Sample														
					Permit Req.					>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU		02/DA - 2 Days Every Week	GR - GRAB
					Value NODI						C - No Discharge				C - No Discharge				
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample														
					Permit Req.	<=	12510 MO AVG	<=	22518 WKLY AVG	26 - lb/d		<=	25 MO AVG	<=	45 WKLY AVG	19 - mg/L		02/DA - 2 Days Every Week	CP - COMPOS
					Value NODI		C - No Discharge		C - No Discharge						C - No Discharge				
00600	Nitrogen, total [as N]	1 - Effluent Gross	0	--	Sample														
					Permit Req.							Req Mon MO AVG			19 - mg/L		01/30 - Monthly	CP - COMPOS	
					Value NODI							C - No Discharge							
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	5	--	Sample														
					Permit Req.	<=	1251 MO AVG	<=	2502 DAILY MX	26 - lb/d		<=	2.5 MO AVG	<=	5 DAILY MX	19 - mg/L		02/DA - 2 Days Every Week	CP - COMPOS
					Value NODI		C - No Discharge		C - No Discharge						C - No Discharge				
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample														
					Permit Req.							Req Mon MO AVG			19 - mg/L		01/30 - Monthly	CP - COMPOS	
					Value NODI							C - No Discharge							
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample														
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	03 - MGD							99/99 - Continuous	RT - RCOTOT	
					Value NODI		C - No Discharge		C - No Discharge										
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample														
					Permit Req.							<=	.15 MO AVG	<=	.75 DAILY MX	19 - mg/L		05/DW - 5 Days Every Week	GR - GRAB
					Value NODI								C - No Discharge		C - No Discharge				
74055	Coliform, fecal general	1 - Effluent Gross	0	--	Sample														
					Permit Req.									<=	400 DAILY MX	13 - #/100mL		05/DW - 5 Days Every Week	GR - GRAB
					Value NODI										C - No Discharge				
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample														
					Permit Req.	<=	10008 MO AVG	<=	20016 WKLY AVG	26 - lb/d		<=	20 MO AVG	<=	40 WKLY AVG	19 - mg/L		02/DA - 2 Days Every Week	CP - COMPOS
					Value NODI		C - No Discharge		C - No Discharge						C - No Discharge				

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

No attachments.

Report Last Saved By

GREATER PEORIA SANITARY AND SEWAGE DISTRICT

User:	mgibbs@gpsd.org	Date/Time:	2016-07-15 14:51 (Time Zone: -05:00)
Name:	Mike Gibbs		
E-Mail:	mgibbs@gpsd.org		

DMR Copy of Record

Permit			
Permit #:	IL0021288	Permittee:	GREATER PEORIA SANITARY AND SEWAGE DISTRICT
Major:	Yes	Permittee Address:	2322 SOUTH DARST STREET PEORIA, IL 61607
Permitted Feature:	004 External Outfall	Discharge:	004-0 INFILTRATION WATER DECANT
Facility:		Facility Location:	GREATER PEORIA SANITARY AND SEWAGE DISTRICT 2322 SOUTH DARST STREET PEORIA, IL 61607

Report Dates & Status

Monitoring Period:	From 06/01/16 to 06/30/16	DMR Due Date:	07/25/16	Status:	NetDMR Validated
--------------------	---------------------------	---------------	----------	---------	------------------

Considerations for Form Completion

NUMBER OF DAYS OF DISCHARGE:CS

Principal Executive Officer

First Name:		Title:		Telephone:	
Last Name:					

No Data Indicator (NODI)

Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Sample	Quantity or Loading				Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type	
						Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--	Sample														
					Permit Req.														
					Value NODI														
00400	pH	1 - Effluent Gross	0	--	Sample														
					Permit Req.														
					Value NODI														
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample														
					Permit Req.														
					Value NODI														
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	0	--	Sample														
					Permit Req.														
					Value NODI														
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample														
					Permit Req.														
					Value NODI														
74055	Coliform, fecal general	1 - Effluent Gross	0	--	Sample														
					Permit Req.														
					Value NODI														
82220	Flow, total	1 - Effluent Gross	0	--	Sample														
					Permit Req.														
					Value NODI														

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

No attachments.

Report Last Saved By

GREATER PEORIA SANITARY AND SEWAGE DISTRICT

User:	mgibbs@gpsd.org	Date/Time:	2016-07-15 14:51 (Time Zone: -05:00)
Name:	Mike Gibbs		
E-Mail:	mgibbs@gpsd.org		

DMR Copy of Record

Permit		Permittee:		Facility:															
Permit #:	IL0021288	GREATER PEORIA SANITARY AND SEWAGE DISTRICT		GREATER PEORIA SANITARY AND SEWAGE DISTRICT															
Major:	Yes	Permittee Address: 2322 SOUTH DARST STREET PEORIA, IL 61607		Facility Location: 2322 SOUTH DARST STREET PEORIA, IL 61607															
Permitted Feature:	INF Influent Structure	Discharge: INF-L INFLUENT MONITORING																	
Report Dates & Status																			
Monitoring Period:	From 06/01/16 to 06/30/16	DMR Due Date:	07/25/16	Status:	NetDMR Validated														
Considerations for Form Completion																			
CS																			
Principal Executive Officer																			
First Name:	Stanton	Title:	Executive Director	Telephone:	309-637-3511														
Last Name:	Browning																		
No Data Indicator (NODI)																			
Form NODI:	--																		
Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type		
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
00310	BOD, 5-day, 20 deg. C	G - Raw Sewage Influent	0	--	Sample					=	400					19 - mg/L	05/DW - 5 Days Every Week	CP - COMPOS	
					Permit Req.											19 - mg/L	02/DA - 2 Days Every Week	CP - COMPOS	
					Value NODI														
00530	Solids, total suspended	G - Raw Sewage Influent	0	--	Sample					=	282					19 - mg/L	06/07 - Six Every Week	CP - COMPOS	
					Permit Req.											19 - mg/L	02/DA - 2 Days Every Week	CP - COMPOS	
					Value NODI														
50050	Flow, in conduit or thru treatment plant	G - Raw Sewage Influent	0	--	Sample	=	18.23	=	42.13	03 - MGD							99/99 - Continuous	RT - RCOTOT	
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	03 - MGD							99/99 - Continuous	RT - RCOTOT	
					Value NODI														
Submission Note																			
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.																			
Edit Check Errors																			
No errors.																			
Comments																			
Attachments																			
No attachments.																			
Report Last Saved By																			
GREATER PEORIA SANITARY AND SEWAGE DISTRICT																			
User:	pkturi@gpsd.org			Date/Time:	2016-07-15 15:02 (Time Zone: -05:00)														
Name:	Paul Keturi																		
E-Mail:	pkturi@gpsd.org																		